



Dhr. Tom Vandaele
IVC NV
Nijverheidslaan 29
8580 AVELGEM

Your notice of

Your reference

our reference
PW/1537

date
2011-02-11

Certification Report Nr. 11/1537

1. Description of the flooring:

Product group: Textiel
PVC floor covering
Wear layer: 0,18 mm – 0,36 mm
Total mass: 1490 g/m² - 2445 g/m²
Thickness: 2,60 mm – 3,65 mm

2. Executed tests:

European Fire classification in accordance with EN 13501-1 (2002)		
Class	EN ISO 11925-2 (15 s surface flame attack) or EN 14041 (2004)	EN ISO 9239-1 (test duration = 30 min) heat flux $\geq 4,5$ kW/m ²
C _{fl}	E _{fl}	

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose-laid tested on a non-combustible substrate

C_{fl} - s1

This certification report runs to 2 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel.

The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is recognized as notified body 0493 for the European Construction Products directive and the European directive for personal protective equipment

CENTEXBEL GENT
Technologiepark 7
BE-9052 Zwijnaarde (Gent)
Tel. +32 9 220 41 51
Fax +32 9 220 49 55
e-mail gent@centexbel.be

CENTEXBEL BRUSSELS
Montoyerstraat 24-B2
BE-1000 Brussels
Tel. +32 2 287 08 30
Fax +32 2 230 68 15
e-mail brussel@centexbel.be

CENTEXBEL VERVIERS
Avenue du Parc 38
BE-4650 Herve (Chaineux)
Tel. +32 87 32 24 30
Fax +32 87 34 05 18
e-mail chaineux@centexbel.be



Addressee
IVC NV

our ref.
PW/1537

date
2011-02-11

page number
2


Related commercial names to this product group are:

COMFYTEX
REMPA
TEXAS NEW
TEXMARK
TEXTRA
EXTRAMAX
EXTRAZ

The obtained classification is based on the next test reports:

Centexbel: 76441/I of 2010-11-04
Centexbel: 76441/J of 2010-11-04
Centexbel: 76441/K of 2010-11-04

Certificate valid until 2015-11-04


Petra Wittevrongel
certification coordinator