



**Dhr. Geert Spileers**  
**Associated Weavers Europe**  
**Industriezone 1**  
**9600 RONSE**

**Your message - reference**

-

**our reference**

PW/1833

**Gent**

2019-09-06

## Certification report 19/1833

---

### 1. Description of the flooring:

<b>Product family</b>	Tufted broadloom carpet 100% polyamide Woven textile backing
<b>Total mass</b>	1645 g/m <sup>2</sup> - 3980 g/m <sup>2</sup>
<b>Effective pile thickness</b>	4.0 mm – 17.2 mm

### 2. Test results:

#### Classification according to EN 13501-1:2007+A1 (2009)

<b>Class</b>	EN ISO 11925-2 or CWFT (EN 14041 - 2004)	EN ISO 9239-1 (30 min.)
<b>C<sub>fi</sub></b>	E <sub>fi</sub>	heat flux ≥ 4,5 kW/m <sup>2</sup>

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.  
Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



**CENTEXBEL • textile competence centre • [www.centexbel.be](http://www.centexbel.be)**  
**GENT •** Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • [gent@centexbel.be](mailto:gent@centexbel.be)  
**VAT •** BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB



**addressee**

Associated Weavers Europe

**our reference**

PW/1833

**Gent**

2019-09-06

**page**

2

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose-laid tested on a non-combustible substrate<sup>1</sup>

Cfl - s1

<b>Related commercial names to this product group</b>	Dream Charme Origine Wave
<b>The obtained classification is based on the next test reports</b>	Centexbel: 15.01057.01 dd. 2015-03-23 Centexbel: 16.01921.01 dd 2016-05-30 Centexbel: 17.02719.01 dd 2017-05-30 Centexbel: 19.00125.01 dd 2019-02-11 Centexbel: 19.00569.01,02,03,04 dd 2019-02-22
<b>Validity of the certificate</b>	2021-05-30

  
Petra Wittevrongel  
Product Certifier

<sup>1</sup> End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)